

**KANSAS DEPARTMENT OF TRANSPORTATION
SPECIAL PROVISION TO THE
STANDARD SPECIFICATIONS EDITION 2007**

Add a new SECTION in DIVISION 800.

SEPARATION GEOTEXTILE

1.0 DESCRIPTION

Install the separation geotextile at the locations designated in the Contract Documents.

BID ITEM

Separation Geotextile

UNITS

Square Yard

2.0 MATERIALS

Provide a non-woven geotextile that complies with **SECTION 1710** (Special Provision 07-17004, latest revision) and is contained on PQL -48 as a Class 1 geotextile..

3.0 CONSTRUCTION REQUIREMENTS

Place the separation geotextile as shown in the Contract Documents. Overlap the geotextile a minimum of 10 inches.

Place the initial lift of backfill 12 to 24 inches thick (loose measurement) so the construction traffic is not directly upon the separation geotextile.

4.0 MEASUREMENT AND PAYMENT

The Engineer will measure the separation geotextile by the square yard. Material placed beyond the neat lines indicated in the Contract Documents is not measured for payment unless authorized by the Engineer.

Payment for "Separation Geotextile" at the contract unit price is full compensation for the specified work.

04-25-13 M&R(SP) (JJB)
Aug-Letting