

**KANSAS DEPARTMENT OF TRANSPORTATION
SPECIAL PROVISION TO THE
STANDARD SPECIFICATIONS, EDITION 2007**

Delete SECTION 817 and replace with the following:

SECTION 817

PIPE CULVERTS, EROSION PIPE, STORM SEWERS, SANITARY SEWERS AND END SECTIONS

817.1 DESCRIPTION

Install the size and type of pipe culvert, erosion pipe, liner pipe, storm sewer, sanitary sewer, end section and concrete headwall specified in the Contract Documents.

BID ITEMS

Entrance Pipe (*) (**) (+) (++) (^) (^^)
Cross Road Pipe (*) (**) (+) (++) (^) (^^)
Erosion Pipe (*) (**) (+) (++) (^) (^^)
Liner Pipe (*) (**)
Storm Sewer (*) (**) (^) (^^)
Sanitary Sewer (*) (**)
End Section (*) (**) (+) (++)
Concrete Headwall
Fly Ash Slurry Grout (xx)

UNITS

Linear Foot
Linear Foot
Linear Foot
Linear Foot
Linear Foot
Linear Foot
Each
Each
Cubic Yard

*Size

**Type

+Provide Only

++Install Only

xx High Strength or Low Strength

^BC-Bituminous Coated

^^FP-Fully Paved

TYPES OF PIPES

RCP - Round Reinforced Concrete Pipe
RCPA - Reinforced Concrete Pipe-Arch
RCPHE - Reinforced Concrete Pipe Horizontal Elliptical
CSP - Galvanized Round Corrugated Steel Pipe
CSMAC - Galvanized Corrugated Steel - Metal Arch Culvert
ACSP - Aluminized (Type 2) Round Corrugated Steel Pipe
ACSMAC - Aluminized (Type 2) Corrugated Steel - Metal Arch Culvert
CAP - Round Corrugated Aluminum Pipe
CAMAC - Corrugated Aluminum - Metal Arch Culvert
PEP - Polyethylene Pipe
CIP - Cast Iron Pipe
CIPP - Cast Iron Pressure Pipe
CISP - Cast Iron Soil Pipe
PVCP - Polyvinyl Chloride Pipe
HDPE - High Density Polyethylene - Liner Pipe

TYPES OF END SECTIONS

- RC - Round Reinforced Concrete
- RCA - Reinforced Concrete Arch
- RCHE - Reinforced Concrete Horizontal Elliptical
- CS - Galvanized Round Corrugated Steel
- CSMA - Galvanized Corrugated Steel - Metal Arch
- ACS - Aluminized Corrugated Steel
- CA - Round Corrugated Aluminum
- ACSMAC - Aluminized (Type 2) Corrugated Steel - Metal Arch
- CAMA - Corrugated Aluminum - Metal Arch

SIZE DESIGNATIONS FOR ARCH CULVERTS AND HORIZONTAL ELLIPTICAL CULVERTS

Bid item size designations for arch culverts and horizontal elliptical culverts are based on minimum waterway requirements, **TABLE 817-1**. Unless shown otherwise in the Contract Documents, provide CSMAC, ACSMAC, CAMAC, RCPA or RCPHE.

TABLE 817-1: MINIMUM WATERWAY REQUIREMENTS FOR ARCH CULVERTS AND HORIZONTAL ELLIPTICAL CULVERTS			
Bid Item Size Designation (minimum Sq. Ft. area of waterway)	CSMAC/ACSMAC/ CAMAC (Sq. Ft. area of waterway)	RCPHE (Sq. Ft. area of waterway)	RCPA (Sq. Ft. area of waterway)
1.0	1.1	1.8	1.7
1.5	1.6	1.8	1.7
2.0	2.2	3.3	2.2
2.5	2.9	3.3	2.8
3.0	4.5	3.3	4.4
4.0	4.5	4.1	4.4
5.0	6.5	5.1	6.4
6.0	6.5	6.3	6.4
7.0	8.9	7.4	8.8
8.5	8.9	8.8	8.8
10.0	11.6/11.7	10.2	11.4
11.0	11.6/11.7	12.9	11.4
12.5	14.7/15.6	12.9	14.3
14.0	14.7/15.6	16.6	14.3
16.5	18.1/19.3	16.6	17.7

a. Pipe Culverts, Erosion Pipe, Storm Sewer and End Sections. Provide the type of pipe specified in the Contract Documents. If the type of pipe and end section is not specified in the proposal or the plans, provide any of the types permitted in **TABLE 1901-1: USES OF PIPES**. Use the same type of pipe base metal (steel) throughout any individual run, installation of pipe or for pipe extensions. Provide end sections of the same type as the pipe, except as follows:

- Provide CS, ACS, CA or RC with PEP or PVCPC.

b. Sanitary Sewer. Use cast iron pipe of the bell and spigot type.

c. Reinforced Concrete Box Storm Sewer. Construct reinforced concrete box storm sewer in place as shown in the Contract Documents according to **DIVISION 700**.

817.2 MATERIALS

Provide materials that comply with the applicable requirements.

Pipes, Fittings and End Sections	DIVISION 1900
Steel Encasement Pipe	DIVISION 1600
Concrete & Fly Ash Slurry Grout	DIVISION 400
Portland Cement	DIVISION 2000
Water	DIVISION 2400
Coarse, Fine and Mixed Aggregates	DIVISION 1100
Reinforcing Steel	DIVISION 1600
Plastic Joint Compound	DIVISION 1500
Material for Sealing Joints in Pipes	DIVISION 1500
Factory Molded Joints	DIVISION 1500
Flowable Fill	SECTION 843

817.3 CONSTRUCTION REQUIREMENTS

a. General. If PEP or PVC pipe is used, prior to the pre-construction conference, submit for evaluation by the Engineer, a resumé of experience installing PEP or PVC. A representative of the manufacturer of PEP or PVC must attend the pre-construction conference for all projects where the Contractor has minimal or no experience with PEP or PVC installation, or if no resumé is submitted.

If "Provide Only" is specified, provide and deliver the pipe, coupling bands and end sections to the storage location shown in the Contract Documents.

If "Install Only" is specified, KDOT will provide the pipe, coupling bands and end sections. The location of the materials is shown in the Contract Documents.

If neither "Provide Only" or "Install Only" is designated, provide and install the pipe, coupling band and end sections as shown in the Contract Documents.

Use Grade 3.0 concrete to construct headwalls for erosion pipe. Perform formwork, placing, curing and protection of concrete according to **DIVISION 700**.

If aluminum pipe or aluminized corrugated steel pipe is to come in contact with fresh portland cement concrete or grout, completely cover the contact area of the pipe with an asphaltic paint (approved by the Field Engineer) to prevent corrosion.

b. Excavation.

(1) General. Beginning at the outlet end and proceeding toward the upper end, excavate the bottom of the channel to the line, grade and elevation shown in the Contract Documents. Construct the width of the trench sufficient to lay and backfill the pipe with a minimum width equal to the diameter of the pipe plus 6 inches on each side.

Follow OSHA safety regulations for sloping the sides of excavations. Use shoring and bracing as required.

Do not disturb any railroad, existing street or highway, when tunneling underneath is required (See **SECTION 819** for tunneling, jacking or boring requirements). Methods of tunneling are subject to Engineer approval.

When it is required to remove an existing street or highway surface in constructing the pipe or sewer, replace the surface with an equivalent material at Contractor's expense, unless otherwise shown in the Contract Documents.

Firm the foundation in the trench to prevent subsequent settlement. Remove soft, unstable materials and replace with suitable materials. If the foundation is on firm earth, pare or mold the earth to give full support to each pipe for a depth a minimum of $\frac{1}{4}$ the external diameter of the pipe. When bell and spigot pipe is used, cut notches to receive the bell.

The Contractor may undercut the trench and backfill with sand or other suitable material to obtain proper, uniform bearing of the pipe at no additional cost to KDOT.

If rock is encountered, remove the rock to an elevation 12 inches below the elevation shown in the Contract Documents for the bottom of the channel. If blasting is used to remove rock, take the precautions to protect the previously placed portions of the structure. Backfill and compact the bottom 12 inches of the excavation with soil

from the roadway excavation. If the foundation is in rock, place an equalizing bed a minimum of 6 inches thick of well-compacted sand or similar material upon the rock.

When shown in the Contract Documents, or ordered in writing by the Engineer, place a concrete cradle or encasement under or around the pipe to provide a suitable foundation for the pipe. Use the dimensions and grade of concrete as shown in the Contract Documents, or as directed by the Engineer.

(2) Pipes and Culverts 3 feet or less in diameter. While excavating, use a template to shape the bottom of the channel so that at least 10% of the overall height of the pipe or culvert is in contact with the bottom of the channel. Excavate recesses into the channel to accept all protrusions from the perimeter of the pipe or culvert.

Alternate methods of bedding the pipe or culvert:

- Place a bed of granular material (4 inch minimum thickness) on the bottom of the channel, and then use a template to shape the granular material to accept the culvert.
- Place the pipe or culvert on the bottom of the channel, then place and tamp granular material (4 inch minimum thickness) under the haunch area of the pipe or culvert.

(3) Pipes and Culverts greater than 3 feet in diameter. Excavate recesses into the channel to accept all protrusions from the perimeter of the pipe or culvert. After the pipe or culvert is placed on the bottom of the channel, place and tamp granular material under the haunch area of the pipe or culvert so that 20% of the overall height of the pipe or culvert is bedded in the granular material.

An alternate method of bedding the pipe or culvert is to place and compact a bed of granular material (approximately half the total quantity needed) on the bottom of the channel, then use a template to shape the granular material to accept the pipe or culvert. Place and tamp the remainder of the granular material after the pipe or culvert is placed so that 20% of the overall height of the pipe or culvert is bedded in the granular material.

(4) Polyethylene (PEP) and Polyvinyl Chloride (PVC) Pipe. Excavate and form a bed for PEP and PVC according to **subsections 817.3b.(1) thru (3)** and the following additions and exceptions:

- The minimum trench width = $(1 \frac{1}{2} \times \text{pipe diameter}) + 12$ inches.
- The space between the pipe and the trench wall shall be wider than the compaction equipment used in the pipe zone.
- The trench width in unsupported, unstable soils will depend on the size of the pipe, the stiffness of the backfill and insitu soil, and the depth of cover.
- Place a 6 inch (minimum) equalizing bed of pipe backfill (PB) as specified in **SECTION 1107 and Special Provision 07-11003** (latest revision) upon the foundation.

c. Laying. Do not lay pipe until the Engineer approves the foundation bed.

(1) General. When placing 2 or more pipe culverts adjacent to each other, separate the pipe culverts by a distance equal to a minimum of $\frac{1}{2}$ the diameter of the pipe. The minimum distance for pipe culverts is 18 inches, and the minimum distance for metal arch culverts is 24 inches.

Before installing corrugated steel pipe, repair any damage to the metallic coating on the pipe. Clean the damaged area to bright metal by blast cleaning, power disk sanding or wire brushing. Apply zinc-rich paint over the cleaned area. Use zinc-rich paint to repair both aluminized and galvanized coatings.

Before installing asphalt coated pipe, repair any damage to the asphalt coating on the pipe. Use material that is compatible with the original asphalt coating. The repaired area shall have the same thickness as the original asphalt coating. For erosion pipe, weld any bends or angles prior to applying the asphalt coating.

In finished trenches, start laying pipe at the outlet end so the spigot ends (when bell and spigot pipe is used) point to the direction of flow. Install all pipes true to line and grade, with ends abutting. When using multiple sections of pipe in an individual run, place the longest section at the upstream end, the next longest section at the outlet end, and shorter sections in the middle of the run. When installing helical, corrugated pipe, rotate the sections during installation so that the corrugations on the end of one section match those on the end of the adjoining section. Lay pipe in the bed so the lower portion of each pipe is supported for its entire length to a depth a minimum of $\frac{1}{4}$ the external diameter of the pipe. When laid in the trench, fit and match pipes to form a smooth, uniform invert. Carefully clean bell ends before pipes are lowered into the trenches. Avoid unnecessary handling in the trench when lowering.

Place sections of corrugated metal pipe with the ends abutting and join with the manufacturer's coupling bands. Install and tighten the coupling bands according to the manufacturer's recommendations.

Cement joints of pipe over 24 inches in diameter with a cement mortar or plastic joint compound. Use cement mortar composed of 1 part portland cement and 3 parts fine aggregate mixed with sufficient water to form a

plastic mortar. As each section of pipe is laid, clean the bell or hub of the preceding pipe and fill the bottom portion with mortar. After the pipe is placed, fill the remaining portion of the joint. Smooth finish and wipe clean the inside of the joint. After the initial set, protect the mortar on the outside from the sun using soil or other approved covering. Prepare and apply plastic joint compound according to the manufacturer's recommendations.

On 24 inch or smaller RCP's, use plastic joint compound to join the sections.

(2) Polyethylene (PEP) and Polyvinyl Chloride (PVCP) Pipe. Install PE and PVC pipes according to **subsection 817.3c.** and the following additions and exceptions:

- Assemble PEP and PVCP according to the manufacturer's instructions, starting at the downstream end.
- Properly assemble the gasketed bell and spigot joints to prevent the infiltration of soil fines.
- The maximum allowable opening is 1 inch.
- If the opening is greater than ¼-inch, the bell channel length shall be 4 times the size of the opening.

d. Concrete Headwalls. Construct headwalls for erosion pipe with Grade 3.0 concrete. Formwork, placing, curing and protection of the concrete shall comply with **DIVISION 700**. Place reinforcing steel as shown in the Contract Documents.

e. Backfilling.

(1) General. Do not begin backfilling the pipe until the Engineer approves the pipe installation. Backfill all trenches and excavated areas with suitable material without disturbing or damaging the pipe. Dispose of excess material and leave the area in a neat presentable condition.

Backfill trenches within the embankment or beneath entrances, side roads, sidewalks, other intersecting traveled ways, or those designated in the Contract Documents to the required grade in layers 6 inches (maximum, compacted thickness). Compact to Type A compaction according to **SECTION 205**.

If the top of a pipe or culvert extends above the original ground line, continue the compacted backfill to the top of the pipe culvert. Place the backfill 1½ times the external diameter of the pipe on each side of the culvert for the full width of the roadway embankment. Take the necessary precautions to prevent distortion of the pipe or culvert while backfilling.

When approved by the Engineer, granular material (of sufficient moisture content and that may be adequately rolled or tamped in place) may be used for backfill material. Place granular material in uniform layers a maximum of 12 inches thick. When deemed necessary by the Engineer, terminate the granular backfill material a minimum of 8 inches below the subgrade or ground level, and use suitable soil to backfill the remaining portion.

If it is necessary for construction equipment to travel over CAP, CSP, PE or PVC before the backfill is completed above the top of the culvert, place additional backfill over the top of the pipe. Use **TABLE 204-1** as a guide.

TABLE 204-1: APPROXIMATE MINIMUM COVER OVER THE TOP OF THE PIPE				
Size (inches)	Approx. Min. Cover Required for Axle Load of 18 to 50 Kip (feet)	Approx. Min. Cover Required for Axle Load of 50 to 75 Kip (feet)	Approx. Min. Cover Required for Axle Load of 75 to 110 Kip (feet)	Approx. Min. Cover Required for Axle Load of 110 to 150 Kip (feet)
CAP and CSP				
12 to 42	2.0	2.5	3.0	3.0
48 to 72	3.0	3.0	3.5	4.0
78 to 120	3.0	3.5	4.0	4.0
PE and PVC				
12 to 36	2.0	2.5	3.0	3.0
42 to 48	3.0	3.0	3.5	4.0
54 to 60	3.0	3.0	3.5	4.0

(2) Sewers. On all sewers which do not meet the requirements of **subsection 817.3e.(1), second paragraph**, carefully deposit and satisfactorily tamp the material in uniform layers a maximum of 6 inches thick until the backfill reaches the top of pipe. Backfill and tamp the remainder of the trench either in uniform layers a maximum of 12 inches thick, or completely fill the trench and settle by satisfactory methods of jetting or flushing. Continue operations until the backfill is slightly above ground level.

(3) Erosion Pipe. Install cover over the erosion pipe according to the Contract Documents. Place the cover in lifts 18 inches (maximum, loose measurement), and compact each lift to Type A compaction, **SECTION 205**. On projects where Type B compaction is required on the adjacent roadway, compact the cover according to Type B compaction, **SECTION 205**. Use hand or mechanical tampers or rollers to achieve compaction.

(4) Structural Plate Structures and Metal Pipes Greater than 60 inches. Backfill structural plate structures and metal pipes greater than 60 inches in diameter with granular backfill. Use deflection control measures, including hand tamping, to maintain the original shape of the structure.

(5) Reinforced Concrete Pipe. If the height of fill over the top of a reinforced concrete pipe is greater than 27.5 feet, place the backfill using the imperfect trench method in this manner:

- Place the reinforced concrete pipe in the excavation, as specified.
- Place and compact the earthen backfill to a height above the top of the pipe equal to the external width of the pipe.
- After the backfill is placed and compacted as specified, excavate the compacted earth from the prism directly over the pipe.
- Backfill the resulting trench with earth placed in the loosest possible condition.
- After the trench is filled with loose earth, construct the remainder of the embankment as specified in the Contract Documents.

(6) Polyethylene (PEP) and Polyvinyl Chloride (PVCP) Pipe. Backfill PEP and PVCP according to **subsection 817.3e**, and the following additions and exceptions:

- Backfill PEP and PVCP with either granular backfill or flowable fill, according to **subsection 817.3e**, with these additions and exceptions:
 - If the fill from the top of pipe to the top of the subgrade is 3 feet or less, backfill with granular material to the top of the subgrade.
 - If the fill from the top of pipe to the top of the subgrade is greater than 3 feet, backfill with granular material to a point 1 foot above the top of the pipe.
 - Prevent damaging or floating the pipe during the backfilling operations. Do not deform or damage the pipe while compacting the granular backfill. Hand tamping may be necessary adjacent to the pipe to prevent distortion.
 - The maximum barrel deflection of the pipe (reduction of the barrel nominal base inside diameter) shall not exceed 5%. Use a mandrel to measure the barrel deflection of the pipe. Take the measurement at least 30 days after the installation and backfilling. If oversized diameter pipes are installed, actual inside pipe diameters may need to be considered. Remove, reinstall or replace any pipes deformed more than 5%.

A minimum of 30 days following the installation and backfilling, measure the barrel deflection of each pipe run.

Measure the deflection using a mandrel or any other device (approved by the Engineer) that can physically verify the dimensions of the pipe and is not limited by poor lighting, water-flow, pipe length or other limiting conditions of the installed environment. Measure the deflection in the presence of the Engineer.

Pipes larger than 24 inches may be entered and deflection levels measured directly. Take a measurement once every 10 feet for the length of the pipe.

If a mandrel is used for the deflection test, use a 9 (or greater odd number) arm mandrel, sized to the actual inside diameter of the pipe installed, and inspected by the Engineer prior to testing. Use a properly sized proving ring to check or test the mandrel for accuracy. Pull the mandrel through the pipe by hand with a rope or cable. When applicable, incorporate pulleys into the system to change the direction of pull so that inspection personnel need not physically enter the pipe or manhole.

If any pipes deform between 5% and 7.5%, conduct an evaluation (by a licensed Professional Engineer) and submit to the Engineer for review and approval. In the evaluation consider the severity of the deflection, structural integrity, environmental conditions and the design service life of the pipe. The Engineer may require removal, reinstallation or replacement of the pipe where the evaluation indicates that the deflection could be problematic.

The maximum barrel deflection of the pipe (reduction of the barrel based on the actual inside diameter) is 7.5%. Remove and reinstall or replace, as directed by the Engineer, any pipes deformed more than 7.5%.

c. Cast Iron Pressure Pipes for Sanitary Sewers. Handle according to this specification with the following additions and exceptions.

(1) Handling. Do not injure the pipe or pipe coating. Do not place any pipe or material inside of a pipe or fitting after the coating is applied.

(2) Cutting. Cut the pipe without damaging.

(3) Placing and Laying. While suspended in the sling and before lowering into the trench, the Engineer will inspect the pipe for defects by tapping lightly with a hammer. Damaged pipe will be rejected. Carefully embed the pipe with bell holes excavated so each pipe will rest firmly upon its bed for the full length. After placing a length of pipe in the trench, hold the packing material for the joint around the bottom of the spigot so the packing enters the bell as the pipe is pushed into position. Center the spigot in the bell and push the pipe into position in the required alignment. Lay pipe with the bells facing the direction of laying, except where necessary in making connections with other lines. Position a minimum of 2 lengths of pipe ahead of each joint, with packing installed and earth fill tamped alongside the pipe before the joint is poured, except at closures.

(4) Joints. Before jointing bell and spigot pipe, remove all lumps, blisters, excess coating materials, oil and grease from the bell and spigot ends of the pipe. Rub with a wire brush, wipe clean and dry the outside spigot and inside of the bell. Carefully place the packing, and tightly caulk to a uniform thickness. No loose or frayed ends of fiber may protrude into the space to be filled with joint filler. Carefully inspect each joint and check for proper depth before the joint runner is attached. The depth of lead in lead filled joints shall be a minimum of 2 ¼ inches back of the face of the bell. In a melting pot near the joint to be poured, heat lead to the proper temperature so that when stirred the surface will show a rapid change in color. Before pouring lead, remove all scum. On the outside of the pipe, dam the pouring gate with clay to fill the joint even with the top of the bell. Make each joint with 1 pour completely filling the joint space. Caulk toward the joint gate to secure tight joints without overstraining the bells. If the packing has been insufficiently caulked, permitting the lead to be driven to a depth more than ¼ inch from the face of the bell at any point during caulking, remove the lead and remake the joint.

d. Liner Pipe. Before installing the liner pipe, push or pull a standard test section of liner pipe, or an approved mandrel of the same length and outside diameter, through the section of pipe being rehabilitated to ensure adequate clearances. Repair or remove any obstructions, protrusions, joint offsets, debris or out-of-roundness that could damage the liner pipe or prohibit passage of the liner pipe during the installation operations.

Provide the Project Engineer with a printed copy of the manufacturer's recommendations for installing the liner pipe. Install the liner pipe according to the manufacturer's recommendations. Install the liner pipe with the assistance of a technical representative of the liner pipe manufacturer. The manufacturer's representative will provide technical expertise pertaining to the installation of the liner pipe and filling the annular space between the existing pipe and liner pipe with fly ash slurry grout.

Fill the space between the liner pipe and the existing structure with fly ash slurry grout, according to the pipe manufacturer's recommendations.

817.4 MEASUREMENT AND PAYMENT

The Engineer will measure all types of pipe by the linear foot, along the centerline of the pipe. Gain in pipe length due to the fit of the pipe sections at the coupling bands or joints is not measured for payment.

The Engineer will measure each end section and concrete headwall.

The Engineer will measure fly ash slurry grout by the cubic yard.

The Engineer will not measure excavation for separate payment.

Payment for "Entrance Pipe", "Cross Road Pipe", "Erosion Pipe", "Liner Pipe", "Storm Sewer", "Sanitary Sewer", "End Section", "Concrete Headwall" and "Fly Ash Slurry Grout" at the contract unit prices is full compensation for the specified work.

SECTION 1901

USES OF PIPE

Page 1900-1, subsection 1901.1. Delete TABLE 1901-1 and replace with the following:

TABLE 1901-1 - USES OF PIPE									
Type of Pipe	AASHTO, ASTM or Specification Class	Type of Construction							Spec.
		Cross Road	Side road & Entrance	Storm Sewer	Under-drain (type)	Under-drain Outlet (type)	Sanitary Sewer	Erosion	
Reinforced Concrete (Arch)	A-II, A-III or A-IV	X	X	X					1902
Reinforced Concrete (Round)	II, III, IV or V	X	X	X					1902
Reinforced Concrete (Horizontal Elliptical)	HE-II, HE-III or HE-IV	X	X	X					1902
Cast Iron Soil							X		1903
Cast Iron or Ductile Iron Pressure	As shown on the Contract Documents						X		1903
Corrugated Steel (Circular or Arch) ³		X ²	X ²	X ²	F ¹	G ¹		X	1904 & 1905
Corrugated Steel (Bituminous Coated Arch)		X ²	X ²	X ²				X	1906
Corrugated Steel (Bituminous Coated Circular)		X ²	X ²	X ²				X	1906
Corrugated Aluminum (Circular or Arch)		X	X	X	F ¹	G ¹		X	1904 & 1905
Corrugated Aluminum (Bituminous Coated Arch)		X	X	X				X	1906
Corrugated Aluminum (Bituminous Coated Circular)		X	X	X				X	1906
Corrugated Steel (Bituminous Coated Circular Fully Paved)		X ²	X ²	X ²					1906
Corrugated Aluminum (Bituminous Coated Circular Fully Paved)		X	X	X					1906
Corrugated Polyethylene Tubing					L ¹	E ¹			1907
Polyethylene (PE) ⁴		X ²	X	X ²					1908
Polyvinyl Chloride (PVC) ⁵		X ²	X	X ²	H ¹	K ¹	X		1909

¹The letter signifies the underdrain type designation as shown in **DIVISION 800**.
²Consult the KDOT pipe policy for locations and applications where the use of CSP, PE or PVC is prohibited. Contact the Bureau of Materials and Research for additional information.
³Includes zinc coated (galvanized) and aluminum alloy (aluminized) coated pipe and pipe-arches provided under **SECTION 1904**. Consult the KDOT pipe policy for locations and applications where the use of galvanized CSP and aluminized CSP is prohibited.
⁴Maximum size (nominal) = 60 inches.
⁵Maximum size (nominal) = 36 inches.

SECTION 1904

CORRUGATED METAL PIPE AND END SECTIONS

Page 1900-8, subsection 1904.2b.(1). Delete this subsection and replace with the following :

(1) Comply all corrugated steel (galvanized and aluminized) pipe, pipe-arches, and accessory items with AASHTO M 36. Comply all steel sheet utilized to fabricate the pipe and pipe-arches with AASHTO M 218 when zinc coated, or AASHTO M 274 when aluminum alloy coated. The type of pipe, and type and class of coating will be specified in the Contract Documents. Provide only continuous helical (lock or welded) seams. Do not interconnect components with differing coating types within a piping system.

Page 1900-8, subsection 1904.2b.(2). Delete this subsection and replace with the following :

(2) Comply all corrugated aluminum alloy pipe, pipe-arches, and accessory items with AASHTO M 196. The type of pipe will be specified in the Contract Documents. Provide only continuous helical lock seams. Do not interconnect metal aluminum alloy pipe with metal steel pipe or accessory items except as permitted through M 196.

SECTION 1908

POLYETHYLENE (PE) PIPE

Page 1900-13, subsection 1908.2a.(1). Delete the first bullet and replace with the following:

- Only Type S is acceptable.

Page 1900-13, subsection 1908.2a.(4). Delete this subsection and replace with the following:

- b. Joints.** To obtain soil tight joints, manufacture the pipe joints to comply with the following:
- Maximum opening is 1 inch.
 - For openings over 1/8-inch, exceed the channel length by 4 times the size of the opening. Channel length is the length of the path that the soil must infiltrate.

Page 1900-13, subsection 1908.2b. Delete this subsection and replace with the following:

c. End Sections. Provide only corrugated metal or precast concrete end sections that comply with the sizes and dimensions in the Contract Documents, and applicable **SECTION 1902** or **1904**. Connect the dissimilar materials using a soil tight connection approved by the Engineer.

Page 1900-13, subsection 1908.2c. Delete this subsection.

Page 1900-13, subsection 1908.2d. Delete this subsection and replace with the following:

d. Provide the same product as tested under the AASHTO National Transportation Product Evaluation Program (NTPEP).

Page 1900-13, subsection 1908.4. Delete the first paragraph and replace with the following:

Supply samples to the AASHTO National Transportation Product Evaluation Program (NTPEP) for testing. For prequalification, forward an official copy of the NTPEP test report to the Bureau Chief of Materials and Research for evaluation.

Page 1900-14, subsection 1908.5. Delete the last sentence and replace with the following:

Successful testing with a mandrel as outlined in **subsection 817.3b**.

SECTION 1909

POLYVINYL CHLORIDE (PVC) PIPE

Page 1900-15, subsection 1909.2. Delete this subsection and replace with the following:

a. Polyvinyl Chloride Pipe. Provide polyvinyl chloride (PVC) for storm sewers and culverts that comply with one of the following:

(1) AASHTO M 304 (Profile Wall) with the following additions or exceptions:

- Seamless construction will be required; spiral wound pipe will not be allowed.
- ASTM D 1784, use only Cell Classification of 12454C.

(2) AASHTO M 278 (Smooth wall), or ASTM F 679 (Large Diameter Sewer Pipe).

- ASTM D 1784, use only Cell Classification of 12454.

b. Joints. To obtain soil tight joints, manufacture the pipe joints to comply with the following:

- Maximum opening is 1 inch.
- For openings over 1/8-inch, exceed the channel length by 4 times the size of the opening. Channel length is the length of the path that the soil must infiltrate.

c. End Sections. Provide only corrugated metal or precast concrete end sections that comply with the sizes and dimensions in the Contract Documents, and applicable **SECTION 1902** or **1904**. Connect the dissimilar materials using a soil tight connection approved by the Engineer.

Page 1900-15, subsection 1909.5. Delete the last sentence and replace with the following:

Successful testing with a mandrel as outlined in **subsection 817.3b**.